



NOTES:

1. LEAVE ALL TERMINALS MARKED 'X' CLEAR.
2. LAYOUT OF EQUIPMENT AND SIZE OF PANELS IS IMPORTANT.
3. INDIVIDUAL MASTER SWITCHES ARE RECOMMENDED TO ALLOW MAINTENANCE WITHOUT AFFECTING ALL CUSTOMERS.
4. CONTACTORS ARE NO LONGER TO BE USED IN MULTIPLE FLAT SITUATIONS. ONE OR MORE RIPPLE RELAYS SHALL BE USED FOR HOT WATER CONTROL. SPECIALLY PROGRAMMED RELAYS FOR THIS PURPOSE ARE AVAILABLE ON REQUEST, AND CAN CONTROL UP TO 3 INDIVIDUAL LOADS PER RELAY
5. DEPENDING ON THE No. of FLATS 3 H/w FEEDS CAN BE SUPPLIED FROM 1 RELAY BY USING 3 LOAD SWITCHES
I.E 21 FLATES = 7 RELAYS

© Copyright Metrix 2000

△				
△				
△	MASTER SWITCH ADDED	ND	BC	05/02
△	GENERAL ISSUE	ND	BC	12/2000
REV	DESCRIPTION OF REVISION	BY	CHK	DATE

METRIX

42 OLIVE RD PENROSE
PRIVATE BAG 92008 AUCKLAND
Phone: (09) 580 3900 Fax: (09) 580 394

METER WIRING SINGLE PHASE RESIDENTIAL OP FOR MULTIPLE RESIDENCES WITH COMBINED METER BOARDS			
Designed	METRIX	Checked	B.CAMERON
Date	12/2000	Approved	T.De VILLIERS
Drawn	N.DUKE	Cad File Name	MX00013801.DWG

SCALE	NTS
DRAWING CONTINUED ON SHEET:	
DRAWING NUMBER	REVISION
MX-000138-01	B