


CT CIRCUIT DIAGRAM



	TYPE	TAP RATING			
	MR6	5A	150A	300A	600A
	MR10	5A	500A	1000A	2000A

NOTE 1. CONDUCTOR Y/Wh TO BE CONNECTED TO APPROPRIATE CT TAP TERMINAL S2, S3 OR S4 FOR DESIRED RATIO

© Copyright Metrix 2000

REV	DESCRIPTION OF REVISION	BY	CHK	DATE
△				
△	TERMINATION REVISED	ND	BC	05/02
△	GENERAL ISSUE	ND	BC	12/2000

METRIX

42 OLIVE RD PENROSE
PRIVATE BAG 92008 AUCKLAND
Phone: (09) 580 3900 Fax: (09) 580 394

KAPPA CURRENT TRANSFORMER
GENERAL ARRANGEMENT
DRAWING

Designed	METRIX	Checked	B.CAMERON	Date	12/2000
Drawn	N.DUKE	Approved	T.De VILLIERS	Cad File Name	MX00000102.DWG

SCALE	NTS
DRAWING CONTINUED ON SHEET:	
DRAWING NUMBER	REVISION
MX-000001-02	B